



HYDROGEOLOGIC DATABASE Chemical Analysis

[Click HERE to View Information for Well 8JB](#)

Sample Results Color Code Legend

Sample Exceeds [None
Secondary
Primary] **MCL**



Owner Name: **Bill Kolwes**

Well Key: **8JB**

Site Type: **Well**

TRS: **29N/02E-01A**

PWS Name: **Goodell Road Water System**

DOH PwsID: **64821** DOH Source #: **1**

		Bicarbonate			Conductivity		Hardness			Turbidity						
Source	Date	Alk	As	Ca	Cl	Fe	K	Mg	Mn	Na	NO3	SO4	TDS			
Other	3/26/1990		< 0.01		13	270	0.10	110		< 0.01	11	1.2	17	< 0.5		
DOH	9/15/2005										2.85					
DOH	12/11/2008										2.65					
Other	9/6/2012				14	335					3.2					
DOH	7/22/2014										3.3					
DOH	10/10/2019										2.92					

Select Summary Statistics

Avg As:	0.005	Avg Cl:	13.5	Avg Hardness:	110	Avg NO3:	2.69
Median As:	0.005	Median Cl:	13.5	Median Hardness:	110	Median NO3:	2.885
Max As:	0.005	Max Cl:	14.0	Max Hardness:	110	Max NO3:	3.3

Bacteria Samples (distribution): [7 sample\(s\)](#)

Disclaimer: Data presented has been collected from a variety of sources. Island County makes no guarantee as to the validity or accuracy of this data.
Please report any errors to the Island County Hydrogeologist.

Generated by the Island County Hydrogeologic Database

6 records printed on 11/4/2019

Note: Items with [blue frames and blue text](#) are clickable hyperlinks to additional information / resources.

Parameter labels with a [red fill color](#) are exhibiting an increasing trend, and those with a [green fill color](#) are exhibiting a decreasing trend.